

**ADDENDUM NO. 2
FOR
CITY OF CUMMING
SECURITY IMPROVEMENTS**

ADDENDUM DATE: OCTOBER 2, 2020

REVISED PROPOSAL DATE: OCTOBER 7, 2020

This **ADDENDUM** is issued to institute the included changes and/or deletions to the Plans and Specifications for the **CITY OF CUMMING – SECURITY IMPROVEMENTS** project and hereby becomes a part of said Plans and Specifications.

Where an item on the original Plans and Specifications is amended, voided, or superseded by a modification contained in the **ADDENDUM**, the provisions of such item not specifically amended, voided, or superseded shall remain in effect.

CONTRACTOR QUESTIONS

1. Specifications 2.4 ALL AND 3.3A indicate that the electrical contractor will need to furnish engineering services.
Engineering services are not required.
2. Specifications 3.5B indicate that the electrical contractor is responsible for spoilage removal.
There is no spoilage to be removed.
3. Specifications 3.5 and 3.9 indicate extensive labeling and temporary power requirements.
The only labeling required is on the new panels provided by the Security Systems manufacturer. Temporary power is not required.
4. The drawings are not clear as to which underground raceways are new and need to be installed and which are existing.
The only underground raceway needed is for the CCTV located at the gate at the water treatment plant.
5. The drawings are not clear as to where the panels are located for the 120-volt power in relation to where the circuits are needed.
The new panels should be located within 25 feet of the 120v power panels.

Please acknowledge receipt of ADDENDUM NO. 2 by initialing and providing company name in the spaces provided below and e-mail to gil@cecincga.com.

Thank you.

YES, _____, of _____

has received ADDENDUM NO. 2