

**ADDENDUM NO. 2  
FOR  
CITY OF CUMMING  
LANIER PARKWAY BOOSTER PUMP STATION AND WATER TANK**

**ADDENDUM DATE: OCTOBER 9, 2020**

**PROPOSAL DATE: OCTOBER 14, 2020**

This **ADDENDUM** is issued to institute the included changes and/or deletions to the Plans and Specifications for the **CITY OF CUMMING – LANIER PARKWAY BOOSTER PUMP STATION AND WATER TANK** project and hereby becomes a part of said Plans and Specifications.

Where an item on the original Plans and Specifications is amended, voided, or superseded by a modification contained in the **ADDENDUM**, the provisions of such item not specifically amended, voided, or superseded shall remain in effect.

**CONTRACT TECHNICAL SPECIFICATIONS**

1. SECTION 33 16 19.01 STEEL ELEVATED TANK, REVISE paragraph 2.4.C.1 to read:  
An 8-inch diameter inlet/outlet pipe shall be provided from the bottom of the tank to a flanged connection at the base of the support structure. The inlet/outlet pipe shall be carbon steel (Schedule 40) with welded connections and have a thickness not less than 1/4 inch. The inlet/outlet pipe shall have an expansion joint above the base bend.”
  
2. SECTION 44 42 46.01 HYDRODYNAMIC MIXING SYSTEM, REVISE paragraph 2.2.E. to read:  
“
  - E. Carbon Steel Pipe and Fittings
    - A. Carbon steel pipe and fittings shall conform to the associated standards listed: Reference Standards.
    - B. Dimensions for carbon steel fittings shall conform to AWWA C110, unless otherwise specified.
    - C. Piping shall be Schedule 40 carbon steel.
    - D. All flanges shall be plate ring flanges, unless otherwise specified on the drawings. Flange drilling pattern shall be in accordance with ANSI B16.1/B16.5 standards.
    - E. Ring flanges shall be continuously welded on both sides.
    - F. All welded joints shall be free of sharp edges and burrs.
    - G. All shop welds shall be manually scrubbed or brushed with non-metallic pads or stainless-steel wire brushes to remove weld discoloration. Welds to be chemically passivated with nitric or citric acid.

**ADDENDUM NO. 2  
FOR  
CITY OF CUMMING  
LANIER PARKWAY BOOSTER PUMP STATION AND WATER TANK**

- H. Field welding of carbon steel pipe and fittings will not be allowed unless approved by the Engineer.”

**Please acknowledge receipt of ADDENDUM NO. 2 by initialing and providing company name in the spaces provided below and e-mail to [gil@cecincga.com](mailto:gil@cecincga.com).**

**Thank you.**

**YES, \_\_\_\_\_, of \_\_\_\_\_**

has received ADDENDUM NO. 2